



# Aquatic Facility Inspection Report



Houston Department of Health and Human Services  
Environmental Health Division  
Consumer Health Services Bureau  
Phone: 832.393.5100 Fax: 832.393.5208  
www.houstontx.gov

Facility Name **America s Inn**

Acct # **104320**

Address **10552 SOUTHWEST FRWY**

Zip **77074**

Owner **HADI DHUKKA**

Type Insp  
**Follow-up  
(reinspection) (02)**

Date **06/27/2018**

Facility Type **Hotel/Motel**

Location **S1425B**

Arrival  
**09:20 AM**

Departure  
**10:40 AM**

Telephone  
**7132709559**

Email  
**Americasinn@sbcglobal.net**

District  
**6**

## Water Quality

pH	NT	Free Chlorine	2.40	Bromine	
Temperature		Combined Chlorine		Cyanuric Acid	
Citation(s)					

## OBSERVATIONS AND CORRECTIVE ACTIONS

Code	Items in violation to be corrected by the date indicated	Correct By
265.185e(2)	General Construction/Design - In post-10/01/99 spas, the maximum user load shall not exceed 1 person per 10 square feet of water surface area. (!)Provide spa capacity sign.	06/29/2018

## COMMENTS

Violations corrected. Pool may re-open.

A.J Ali

Date 06/27/2018

Omar Caraballo

Date 06/27/2018

Environmental Investigator